

ASBESTOS CORE TEST

Prepared especially for :

TREMCO INC
3777 Green Rd

Beachwood, OH 44060
January 06, 2003

Copyright Tremco Incorporated 1999
3735 Green Road
Beachwood, Ohio 44122-8061
All Rights Reserved

ASBESTOS CORE TESTING

Asbestos Core Testing represents the state of the art laboratory analysis for asbestos in roofing materials. The results of this analysis are based on findings derived from extensive laboratory analysis of individual roof core samples. Tremco accepts no liability or responsibility for any cost associated with asbestos contained materials which were not sampled or analyzed for asbestos content for inclusion in this report. The laboratory (NVLAP LAB Code 101188) is accredited by the U.S. Department of Commerce, National Institute of Standards and Technology, National Voluntary Laboratory Accreditation Program (NVLAP) to provide Asbestos fiber analysis by the NVLAP Test Method Code 18/A01 - Test Method Designation: 40 Code of Federal Regulations Chapter I (1-1-87 edition) Part 763, Subpart F, Appendix A, Pages 292-299 of the current U.S. Environmental Protection Agency method for the analysis of asbestos in building materials by polarized light microscopy. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the United States Government. This report contains data that are not covered by the NVLAP accreditation.

The presence of asbestos in your roofing system may have significant consequences for any actions planned in the future of your roofing system. The impact may not only be performance related but may be due to the regulations concerning the presence and handling of asbestos in your facility's structure. It is important that you be aware of legal ramifications of asbestos in your roofing system before any work is planned.

ACT ANALYTICAL REPORT FOR TREMCO INC

ASBESTOS CORE TESTING

Core: **Core #1**

Identification Number: **01**

NVLAP Test Code: **18/A01**

NVLAP Lab Code: **101188**

Test Method: **EPA/600/R-93/116**

Treatment: **Methylene Chloride Solvent Extraction**

Homogeneity: **Layered**

Layer	Color	Asbestos	Other Fibrous	Nonfibrous
One	white	None Detected	Fiberglass 95	Binder 5
Two	white	None Detected	Fiberglass 95	Binder 5
Three	white	None Detected	Fiberglass 95	Binder 5
Four	white	None Detected	Fiberglass 95	Binder 5
MASTIC		None Detected		Asphalt 100
TOTAL		None Detected	Fiberglass 6	Asphalt 84 Binder 10

Comment:

Notice: The results of this analysis are based on findings determined from laboratory analysis of individual roof core samples and include the inherent uncertainty of measurement for estimating percentages by polarized light microscopy. Tremco accepts no liability or responsibility for any costs associated with asbestos containing material which were not sampled or analyzed for asbestos content for inclusion in this report. The result relate only to the items tested; and the report shall not be reproduced except in full, without written approval of the laboratory.

APPROVED: _____ **DATE:** _____